

PORTABLE APPLIANCE +A1:I22 TESTING (PAT) REPORT/CERTIFICATE

Certificate Reference 945621

DETAILS OF CLIENT/LANDLORD

Client address

4 Sidpark Road
Sidmouth
EX10 9BR**TEST EQUIPMENT DETAILS**Test equipment used
Tested by M.Self

MT17 Date 06/06/2023 Serial number 735296451

2024



Serial number/ ID	Make and Model	Location	Voltage	Fuse Rating	Insulation Resistance	Earth Continuity	Plug, Flex and body ok to use
1	Microwave	Kitchen	230	13 >250		✓	✓ ✓ ✓
2	Toaster	Kitchen	230	13 >250		✓	✓ ✓ ✓
3	Kettle	Kitchen	230	13 >250		✓	✓ ✓ ✓
4	Hand Blender	Kitchen	230	3 >250		✓	✓ ✓ ✓
5	Lamp	Kitchen	230	3 >250		✓	✓ ✓ ✓
6	Henry Hoover	Kitchen	230	13 >250		✓	✓ ✓ ✓
7	Iron	Kitchen	230	13 >250		✓	✓ ✓ ✓
8	Lamp	lounge	230	3 >250		✓	✓ ✓ ✓
9	Lamp	lounge	230	3 >250		✓	✓ ✓ ✓
10	Lamp	lounge	230	3 Visual		✓	✓ ✓ ✓
11	TV	lounge	230	3 Visual		✓	✓ ✓ ✓
12	DVD	lounge	230	3 Visual		✓	✓ ✓ ✓
13	Speaker	lounge	230	3 Visual		✓	✓ ✓ ✓
14	Lamp	Bedroom 1	230	3 >250		✓	✓ ✓ ✓
15	Lamp	Bedroom 1	230	3 >250		✓	✓ ✓ ✓
16	Lamp	Bedroom 1	230	3 >250		✓	✓ ✓ ✓
17	Lamp	Bedroom 2	230	3 >250		✓	✓ ✓ ✓
18	Radio	Bedroom 1	230	3 >250		✓	✓ ✓ ✓
19	Hairdryer	Bedroom 1	230	13 >250		✓	✓ ✓ ✓