Certificate reference **45212990**

05/06/2024
Date Completed

Portable Appliance Test (PAT) Completion Certificate

DETAILS OF THE CLIENT

Jo Cunningham
4 Sid Park Road
Sidmouth

Postcode: EX10 9BW

ADDRESS OF TESTING

4 Sid Park Road
Sidmouth

Postcode: EX10 9BW

ENGINEER, NAME & SIGNATURE

Signature

Name

Mike Self

Date

05/06/2024

*ANY LIMITATIONS AGREED ON TESTING *If any, reasons and with whom agreed

TESTING CARRIED OUT BY

Mike Self Electrical Installations

11 Radway Place
Sidmouth

Ex10 8PY

Email mikeselfelectrical@hotmail.com
Web
Telephone 07875025470

Registration No:
(if applicable)

PAT TESTER SERIAL NUMBER

DECLARATION

This is to certify the electrical appliances details in this certificate and record sheets have been tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical equipment. It does not guarantee the correct operation of the appliance for any length of time. Users of the appliance should be aware of any fault or defect that may occur with future use. Any doubt regarding the safety or correct operation of the appliance, the device should be removed from service for further inspection by a competent person.

ANY FAILED APPLIANCES SHOULD BE REMOVED FROM SERVICE UNTIL THE DEFECT HAS BEEN RECTIFIED

APPLIANCE SUMMARY FOR Jo Cunningham 4 Sid Park Road Sidmouth EX10 9BW

Appliances Passed 19

Appliances Failed 0

19 Total Appliances

PORTABLE APPLIANCE REGISTER

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
001	**Kettle**	2	Yes	Kitchen	001	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
2	**Toaster**	2	Yes	Kitchen	002	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
3	**Microwave**	2	Yes	Kitchen	003	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
4	**Fridge**	2	Yes	Kitchen	004	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
5	**Lamp**	2	Yes	Dinning Area	005	Pass	200	Pass	N/A	✓	5	12	12	**Pass**	
6	**Hoover**	2	Yes	Storage	006	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
7	**Iron**	2	Yes	Storage Area	007	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
8	**Dishwasher**	2	Yes	Kitchen	008	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
9	**Lamp**	2	Yes	Lounge	009	Pass	200	Pass	N/A	✓	5	12	12	**Pass**	
10	**Tv**	2	Yes	Lounge	010	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
11	**Lamp**	2	Yes	Lounge	011	Pass	200	Pass	N/A	✓	5	12	12	**Pass**	
12	**Lamp**	2	Yes	Bedroom 1	014	Pass	200	Pass	N/A	✓	3	12	12	**Pass**	
13	**Speaker**	2	Yes	Lounge	013	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
14	**Lamp**	2	Yes	Bedroom 1	014	Pass	200	Pass	N/A	✓	3	12	12	**Pass**	
15	**Lamp**	2	Yes	Bedroom 1	015	Pass	200	Pass	N/A	✓	3	12	12	**Pass**	
16	**Clock**	2	Yes	Bedroom 1	016	Pass	200	Pass	N/A	✓	5	12	12	**Pass**	

Repair Codes:

A = Replace plug
B = Rewire plug
C = Fit BS1361 sleeved plug
D = Fit rubber plug
E = Fit inline switch
F = Replace IEC lead
G = Replace lead
H = Other

Completed using iCertifi electrical certificates on iOS

...continuation of appliance details and test results

iCertifi PAT Edition

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
17	**Lamp**	2	Yes	Bedroom 2	017	Pass	200	Pass	N/A	✓	3	12	12	**Pass**	
18	**Hair Dryer**	2	Yes	Bedroom 1	018	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	
19	**Hair Dryer**	2	Yes	Bedroom 2	019	Pass	200	Pass	N/A	✓	13	12	12	**Pass**	

Repair Codes:

A = Replace plug
B = Rewire plug
C = Fit BS1361 sleeved plug
E = Fit inline switch
F = Replace IEC lead
G = Replace lead
H = Other